


# Certificate of Conformity

Certificate Number: CN-PV-240028

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen Growatt New Energy Co., Ltd. 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China.
<b>Product:</b>	Hybrid Inverter/Storage Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	WIT 50K-H, WIT 63K-H, WIT 75K-H, WIT 100K-H WIT 50K-A, WIT 63K-A, WIT 75K-A, WIT 100K-A WIT 50K-HE, WIT 63K-HE, WIT 75K-HE, WIT 100K-HE WIT 50K-AE, WIT 63K-AE, WIT 75K-AE, WIT 100K-AE WIT 50K-HU, WIT 63K-HU, WIT 75K-HU, WIT 100K-HU WIT 50K-AU, WIT 63K-AU, WIT 75K-AU, WIT 100K-AU
<b>Brand Name&lt;s&gt;:</b>	GROWATT
<b>Product Complies with:</b>	IEC 61727:2004 Photovoltaic (PV) systems – Characteristics of the utility interface IEC 62116:2014 Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	220509109GZU-001, 15 Jan 2024 220509109GZU-002, 15 Jan 2024

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**  
**Date: 26 January 2024**



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-240028.

Model	WIT 100K-H	WIT 100K-HE WIT 100K-HU	WIT 75K-H	WIT 75K-HE WIT 75K-HU
PV input data				
Max. PV voltage	1100 d.c.V			
MPPT voltage range	180V-800 d.c.V			
Max. input current	32 d.c.A*10			
PV Isc	40 d.c.A*10			
AC input/output data				
Rated input/ output power	100 KW	200/100 KW	75 KW	150/75 KW
Max. input/output apparent power	110 KVA	200/110 KVA	82.5 KVA	150/82.5 KVA
Nominal voltage	3W/N/PE 230V/400 a.c.V			
Max. input/output current	166.7 a.c.A	303/166.7 a.c.A	125 a.c.A	227.3/125 a.c.A
Nominal frequency	50/60 Hz			
Power factor range	1.0 Leading – 1.0 lagging			
Backup power				
Rated AC output power	100 KW		75 KW	
Nominal AC output voltage	230V/400 a.c.V			
Nominal AC output frequency	50/60 Hz			
Battery data				
Battery voltage range	600V-1000 d.c.V			
Max. charging and discharging current	167 d.c.A		125 d.c.A	
Type of battery	Lithium-ion			
Others				
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-30°C - +60°C			
Software version	TO1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-240028.

Model	WIT 63K-H	WIT 63K-HE WIT 63K-HU	WIT 50K-H	WIT 50K-HE WIT 50K-HU
PV input data				
Max. PV voltage	1100 d.c.V			
MPPT voltage range	180V-800 d.c.V			
Max. input current	32 d.c.A*8		32 d.c.A*7	
PV Isc	40 d.c.A*8		40 d.c.A*7	
AC input/output data				
Rated input/ output power	63 KW	126/63 KW	50 KW	100/50 KW
Max. input/output apparent power	69.3 KVA	126/69.3 KVA	55 KVA	100/55 KVA
Nominal voltage	3W/N/PE 230V/400 a.c.V			
Max. input/output current	105 a.c.A	190.9/105 a.c.A	83.3 a.c.A	151.5/83.3 a.c.A
Nominal frequency	50/60 Hz			
Power factor range	1.0 Leading – 1.0 lagging			
Backup power				
Rated AC output power	63 KW		50 KW	
Nominal AC output voltage	230V/400 a.c.V			
Nominal AC output frequency	50/60 Hz			
Battery data				
Battery voltage range	600V-1000 d.c.V			
Max. charging and discharging current	105 d.c.A		83.3 d.c.A	
Type of battery	Lithium-ion			
Others				
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-30°C - +60°C			
Software version	TO1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-240028.

Model	WIT 100K-A	WIT 100K-AE WIT 100K-AU	WIT 75K-A	WIT 75K-AE WIT 75K-AU
AC input/output data				
Rated input/ output power	100 KW	200/100 KW	75 KW	150/75 KW
Max. input/output apparent power	110 KVA	200/110 KVA	82.5 KVA	150/82.5 KVA
Nominal voltage	3W/N/PE 230V/400 a.c.V			
Max. input/output current	166.7 a.c.A	303/166.7 a.c.A	125 a.c.A	227.3/125 a.c.A
Nominal frequency	50/60 Hz			
Power factor range	1.0 Leading – 1.0 lagging			
Backup power				
Rated AC output power	100 KW		75 KW	
Nominal AC output voltage	230V/400 a.c.V			
Nominal AC output frequency	50/60 Hz			
Battery data				
Battery voltage range	600V-1000 d.c.V			
Max. charging and discharging current	167 d.c.A		125 d.c.A	
Type of battery	Lithium-ion			
Others				
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-30°C - +60°C			
Software version	TO1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-240028.

Model	WIT 63K-A	WIT 63K-AE WIT 63K-AU	WIT 50K-A	WIT 50K-AE WIT 50K-AU
AC input/output data				
Rated input/ output power	63 KW	126/63 KW	50 KW	100/50 KW
Max. input/output apparent power	69.3 KVA	126/69.3 KVA	55 KVA	100/55 KVA
Nominal voltage	3W/N/PE 230V/400 a.c.V			
Max. input/output current	105 a.c.A	190.9/105 a.c.A	83.3 a.c.A	151.5/83.3 a.c.A
Nominal frequency	50/60 Hz			
Power factor range	1.0 Leading – 1.0 lagging			
Backup power				
Rated AC output power	63 KW		50 KW	
Nominal AC output voltage	230V/400 a.c.V			
Nominal AC output frequency	50/60 Hz			
Battery data				
Battery voltage range	600V-1000 d.c.V			
Max. charging and discharging current	105 d.c.A		83.3 d.c.A	
Type of battery	Lithium-ion			
Others				
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-30°C - +60°C			
Software version	TO1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.