


# Certificate of Conformity

Certificate Number: CN-PVES-240350

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen Growatt New Energy Co., Ltd. 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China.
<b>Product:</b>	Hybrid Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	WIT 29.9K-XHU, WIT 30K-XHU, WIT 36K-XHU, WIT 40K-XHU, WIT 50K-XHU, WIT 29.9K-XHU2, WIT 30K-XHU2, WIT 36K-XHU2
<b>Brand Name&lt;s&gt;:</b>	GROWATT
<b>Product Complies with:</b>	IEC61683:1999 Photovoltaic systems – Power conditioners – Procedure for measuring efficiency IEC 60068-2-1:2007, IEC 60068-2-2:2007, IEC60068-2-14:2009, IEC60068-2- 30:2005
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	240603050GZU-003, 23 July 2024 240603050GZU-004, 23 July 2024

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**

**Date: 24 July 2024**



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-240350

Model	WIT 29.9K-XHU WIT 29.9K-XHU2	WIT 30K-XHU WIT 30K-XHU2	WIT 36K-XHU WIT 36K-XHU2
PV input data			
Max. PV voltage	1100 d.c.V		
Operated voltage range	180V-1000 d.c.V		
Max. input current per MPPT	40 d.c.A		
PV Isc per MPPT	50 d.c.A		
Number of MPP trackers	3(for model with "XHU2") 4(for model with "XHU")		
Max. input number per MPP tracker	2		
AC input/output data			
Rated input/ output power	59.8/29.9 KW	60/30 KW	72/36 KW
Max. input/output apparent power	59.8/29.9 KVA	66/33 KVA	79.2/39.6 KVA
Nominal voltage	3W/N/PE 230V/400 a.c.V		
Max. input/output current	86.6/43.3a.c.A	95.7/47.8a.c.A	114.8/57.4a.c.A
Nominal frequency	50 Hz		
Power factor range	1.0 Leading – 1.0 lagging		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-240350

Backup power			
Rated AC output power	29.9 KW	30.0 KW	36 KW
Nominal AC output voltage	220V/380 a.c.V 230V/400 a.c.V		
Nominal AC output frequency	50/60 Hz		
Battery data			
Battery voltage range	200V-900 d.c.V		
Max. number of battery input	2(for model with "XHU2") 3(for model with "XHU")		
Max. charging and discharging current	55 d.c.A		
Type of battery	Lithium-ion		
Others			
Ingress protection	IP66		
Operation ambient temperature	-30°C - +60°C		
Software version	TO1.0		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-240350

Model	WIT 40K-XHU	WIT 50K-XHU
PV input data		
Max. PV voltage	1100 d.c.V	
Operated voltage range	180V-1000 d.c.V	
Max. input current per MPPT	40 d.c.A	
PV Isc per MPPT	50 d.c.A	
Number of MPP trackers	4	
Max. input number per MPP tracker	2	
AC input/output data		
Rated input/ output power	80/40 KW	100/50 KW
Max. input/output apparent power	88/44 KVA	110/55 KVA
Nominal voltage	3W/N/PE 230V/400 a.c.V	
Max. input/output current	127.5/63.8a.c.A	159.4/79.7a.c.A
Nominal frequency	50 Hz	
Power factor range	1.0 Leading – 1.0 lagging	

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-240350

Backup power		
Rated AC output power	40 KW	50 KW
Nominal AC output voltage	220V/380 a.c.V 230V/400 a.c.V	
Nominal AC output frequency	50/60 Hz	
Battery data		
Battery voltage range	200V-900 d.c.V	
Max. number of battery input	3	
Max. charging and discharging current	55 d.c.A	
Type of battery	Lithium-ion	
Others		
Ingress protection	IP66	
Operation ambient temperature	-30°C - +60°C	
Software version	TO1.0	

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.