


# Certificate of Conformity

Certificate Number: CN-PV-200044

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specifications /standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen Growatt New Energy Technology CO.,Ltd 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P. R. China
<b>Product:</b>	PV Grid inverter
<b>Ratings &amp; Principle Characteristics:</b>	See Appendix to Certificate of Conformity
<b>Models:</b>	MAX 50KTL3 LV, MAX 60KTL3 LV, MAX 70KTL3 LV, MAX 75KTL3 LV, MAX 80KTL3 LV
<b>Brand Name:</b>	Growatt
<b>Tested according to:</b>	C10/11: ed.2.1, 01 Sep 2019 SPECIFIC TECHNICAL PRESCRIPTIONS REGARDING POWER-GENERATING PLANTS OPERATING IN PARALLEL TO THE DISTRIBUTION NETWORK Type approved for type A
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai 2/F (West Side), No. 707, Zhangyang Road, Free Trade Experimental Area, Shanghai, P. R. China
<b>Test Reports No:</b>	200109129GZU-002

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**

**Date: 19 May 2020**

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200044

### Ratings & Principle Characteristics:

Maximum d.c. input voltage: 1100 Vdc  
Input voltage range: 200-1000 Vdc  
MPPT voltage range (full Load): 500-850 V (for MAX 50KTL3 LV); 520-850 V (for MAX 60KTL3 LV); 600-850 V (for MAX 70KTL3 LV, MAX 75KTL3 LV, MAX 80KTL3 LV);  
Max. input current: 6×26A (for MAX 50KTL3 LV, MAX 60KTL3 LV); 7×26A (for MAX 70KTL3 LV, MAX 75KTL3 LV, MAX 80KTL3 LV);  
PV Isc: 6×32A (for MAX 50KTL3 LV, MAX 60KTL3 LV); 7×32A (for MAX 70KTL3 LV, MAX 75KTL3 LV, MAX 80KTL3 LV);  
Nominal output voltage: 3W/N/PE 230V/400Vac  
Max. output current: 3×80.5 A (for MAX 50KTL3 LV); 3×96.6A (for MAX 60KTL3 LV); 3×112.7 A (for MAX 70KTL3 LV); 3×120.8 A (for MAX 75KTL3 LV); 3×128.8A (for MAX 80KTL3 LV)  
Nominal frequency: 50 Hz  
Max. output power: 55500VA (for MAX 50KTL3 LV); 66600VA (for MAX 60KTL3 LV); 77700VA (for MAX 70KTL3 LV); 83300VA (for MAX 75KTL3 LV); 88800 VA (for MAX 80KTL3 LV)  
Ingress protection: IP65  
Operating temperature range: -25 ~ +60°C  
Software Version: T11.0

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.