


Certificate of Conformity

Certificate Number: CN-PV-240027

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen Growatt New Energy Co., Ltd. 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China
Product:	PV Micro Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	NEO 600M-X, NEO 800M-X, NEO 1000M-X
Brand Name<s>:	GROWATT
Product Complies with:	IEC 61727:2004 Photovoltaic (PV) systems – Characteristics of the utility interface IEC 62116:2014 Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	231218019GZU-001, 24 Jan 2024 231218019GZU-002, 24 Jan 2024

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 29 January 2024



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-240027.

Model	NEO 600M-X	NEO 800M-X	NEO 1000M-X
Max. PV voltage	60Vdc		
MPPT voltage	28-60Vdc		
Max. inputcurrent	2*18A		
PV Isc	2*23A		
Nominal output voltage	230Vac		
Nominal output Frequency	50Hz		
Max. output current	2.61A	3.48A	4.35A
Max. output power	600W	800W	1000W
Max. apparent power	600VA	800VA	1000VA
Power factor range	0.8Leading~0.8Lagging		
Safety level	Class I		
Ingress Protection	IP 67		
Operation Ambient Temperature	-40°C - +65°C		
Software version	GJ1.0		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.